



Textilní zkušební ústav

TEXTILNÍ ZKUŠEBNÍ ÚSTAV, s.p.
(TEXTILE TESTING INSTITUTE)
CERTIFICATION BODY FOR THE CERTIFICATION OF PRODUCTS
VÁCLAVSKÁ 6, 658 41 BRNO, CZECH REPUBLIC

issues

to the producer: **Fatra, a.s., třída Tomáše Bati 1541, 763 61 Napajedla, Czech Republic**
IN: 27465021

TESTIMONIAL

No.: 14 - 190

this testimonial confirms that these products:

ELEKTROSTATIK, DYNAMIK, PRAKTIK
homogeneous vinyl floor coverings

material composition: polyvinylchloride

comply with the requirements of standard:

- **EN ISO 846 Plastics – Evaluation of the action of microorganism (method C: Resistance to bacteria – visual evaluation)**

On the tested samples were visually determined no growth of the bacteria. The test was carried out with bacteria *Pseudomonas aeruginosa*. These samples did not make source of nourishment and they were not decomposed by the test bacteria. On the tested samples were determined no visual changes.


They have been ascertained on the base of microbiological test that assessed products are resistant to activity of bacteria.

This testimonial has been issued on the basis of the application No. COV/14/274 dated 01.12.2012. The base for this testimonial is the test protocol No. CHZ 12/0760 dated 18.12.2012, issued by the accredited test laboratory of TZÚ Brno.

Testimonial was issued: Brno, 10.12.2014

Issued by:

Validity up to: 31.12.2016


Jitka Paulová
Certification Body

